

MAYO 2010

PRADEJON

	CAUDAL m3/dia	ENTRADA									SALIDA							
		pH	Cdtv uS/cm2	SS mg/l	SSV %	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l	pH	Cdtv uS/cm2	SS mg/l	DQO mg/l	DBO5 mg/l	NTK mg/l	NH4 mg/l	Ptot mg/l
1	1522																	
2	1393																	
3	1398	7,5	2880	1220		1946		58,9	22,1	12,6	7,6	3070	19,0	19,2		2,3	0,6	0,3
4	1282																	
5	1169	7,6	3190	152		330					7,3	3240	5,0	12,4				
6	1169																	
7	1831																	
8	2159																	
9	1767																	
10	1170	7,7	2920	148		400					7,3	2260	7,0	22,2				
11	2040																	
12	1810	7,7	2840	156		356	174				7,3	2620	4,0	10,2	2,6			
13	1525																	
14	1308																	
15	1296																	
16	1308																	
17	1564	8,1	3410	170		284					7,5	2920	4,0	16,0				
18	1421																	
19	1191	7,9	3180	160		392					7,4	3030	8,0	21,6				
20	1148																	
21	1148																	
22	1232																	
23	1318																	
24	1020	7,5	2840	210		517					7,3	3030	4,0	15,5				
25	1104																	
26	1382	7,3	3170	124		456					7,2	3000	6,0	13,6				
27	1015																	
28	1300																	
29	1241																	
30	1353																	
31	981	8,0	3410	240		396					7,3	3030	9,0	12,5				













